

*Guide for Using the Hydrogeologic Classification System for Logging Water Well Boreholes by Thomas M. Hanna NGWA Press

13391

STATE OF ALASKA

MARTIN'S WATER WELLS
SRA Box 6472-G
PALMER, ALASKA 99645
745-3888 • Lig. • AA5622

LAS 10534
Lot 7 G10 11

T17N R3W 5m (N49-W54)

Drilling Permit No.

A. D. L. No.

1c. DISTANCE AND DIRECTION FROM ROAD INTERSECTIONS

ANCE AND DIRECTION FROM ROAD INTERSECTIONS
Islet. SHEPARD'S-
SHEPARD'S ISLAND
Address and Area of Well Location

3. OWNER OF WELL: HAAKEN Gryte
Address: 1511 L. ST.
ANCHORAGE AK 99501

4. WELL DEPTH: (final) <u>38</u> ft.	5. DATE OF COMPLETION <u>3 - 24 - 86</u>
6. ☒ Cable tool ☐ Rotary ☐ Driven ☐ Dug ☐ Auger ☐ Jetted ☐ Bored ☐ Other:	
7. USE: ☒ Domestic ☐ Public Supply ☐ Industry ☐ Irrigation ☐ Recharge ☐ Commerical ☐ Test Well ☐ Other:	
8. CASING: ☐ Threaded ☒ Welded diam. <u>6</u> in. to <u>48</u> ft. Depth Weight <u>17</u> lbs./ft. diam. in. to ft. Depth Strickup <u>2</u> ft.	

9. FINISH OF WELL:

Type: _____ Diameter: _____

Slot/Mesh Size: _____ Length: _____

Set between _____ ft and _____ ft.

Backfilling _____ Gravel pack _____

10. STATIC WATER LEVEL: 4 ft. 3/24/86
☐ Above or ☒ Below land surface Date
 Equipment used: WELL Sounder

11. PUMPING LEVEL below land surface and YIELD
20 ft. after 4 hrs. pumping 20 g.p.m.
 ft. after hrs. pumping g.p.m.

12.GROUTING Well Grouted: ☐ Yes ☒ No
Material: ☐ Neat Cement ☐ Other: _____

13. PUMP: (if available) HP _____
Length of Drop Pipe _____ ft. capacity _____ g.p.m.
☐ Subm. ☐ Jet ☐ Centrifugal ☐ Other

14. REMARKS:16. WATER WELL CONTRACTOR'S CERTIFICATION:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief;

Lee's Water Wells

AA5632


Address: SRA BOX 6472-G Palmer AK 99645

Signed: Billy J. Jones
Authorized Representative


Date:

Authorized Representative

USGS Local No. SB17-3-19DC



L/ 1 ISLAND
REPLAT L/283
(6194)



PEDERSON SUB.
RESUB. TR. A-1-A-3
(6440)

HO 13 Tax Map
T17N, R3W, S1M

(KEY INDEX LS 13)

SB 17-3-19 DC