

County code 020

15061

WATER WELL RECORD
STATE OF ALASKA
DEPARTMENT OF NATURAL RESOURCES
Division of Geological & Geophysical Surveys

LOCATION OF WELL (Please complete either 1a, 1b or 1c.)

Drilling Permit No. _____

A.D.L. No. _____

1a. Borough Anch.	Subdivision Finley	Lot 1	Block 	1b. 1/4 qtrs. — of — of — of —	Section No. 	Township N S	Range E W	Meridian
-----------------------------	------------------------------	-----------------	------------------	-----------------------------------	------------------------	-------------------------------	----------------------------	---------------------

1c. DISTANCE AND DIRECTION FROM ROAD INTERSECTIONS

3. OWNER OF WELL:

Address: **Roger Lee**

Street Address and Area of Well Location

2. WELL LOG

Feet Below
Surface

Material Type

Top Bottom

silt, fine sand & gravel	0	18
dry, tight silt	18	64
silty S & G w/ boulders	64	86
brn. till	86	102
hard, tight, gravelly till	102	114
gravelly till, wet	114	154
till w/ streaks of fine gravel	154	245
till w/ fine sand	245	254
grey clay w/ strks. of gravel	254	265
wet gravel	265	270
grey till w/ clay	270	286
sand & gravel w/ strks. of till	286	295
water sand & gravel	295	

4. WELL DEPTH: (final)

295 ft.

5. DATE OF COMPLETION

9 - 22 - 87

6. ☒ Cable tool ☐ Rotary ☐ Driven ☐ Dug
☐ Auger ☐ Jetted ☐ Bored ☐ Other:

7. USE: ☒ Domestic ☐ Public Supply ☐ Industry
☐ Irrigation ☐ Recharge ☐ Commercial
☐ Test Well ☐ Other:

8. CASING: ☐ Threaded ☒ Welded
diam. **6** in. to **295** ft. Depth Weight **17** lbs./ft.
diam. _____ in. to _____ ft. Depth Sticksup _____ ft.

9. FINISH OF WELL:

Type: **open bottom** Diameter: _____

Slot/Mesh Size: _____ Length: _____

Set between _____ ft. and _____ ft.

Backfilling _____ Gravel pack _____

10. STATIC WATER LEVEL: **183** ft. **9/22/87**☐ Above or ☒ Below land surface

Date

Equipment used: **dart valve bailer**

11. PUMPING LEVEL below land surface and YIELD

203 ft. after **2** hrs. pumping **10** g.p.m.

_____ ft. after _____ hrs. pumping _____ g.p.m.

12. GROUTING Well Grouted: ☐ Yes ☒ NoMaterial: ☐ Neat Cement ☐ Other:13. PUMP: (if available) HP **Sta-Rite 3P4E02P**

Length of Drop Pipe _____ ft. capacity _____ g.p.m.

☒ Subm. ☐ Jet ☐ Centrifical ☐ Other14. REMARKS: **TPL: 298' 1/2"**

16. WATER WELL CONTRACTOR'S CERTIFICATION:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief;

Dotten Drilling Co.**AA0512**

Registered Business Name

Contract License Number

Address: **8537 Hartzell Road Anchorage, Alaska****99507**Signed: **P. D. L. H.**Date: **9/25/87**

Authorized Representative

Anchorage May 1987

USGS Local No.

58 12-3-15CC042-100
610738 149475601