

This log found within
well number 19559 T
505-10-6 0000

SC 1-14-34 NL 23

SAMPLE DATA SHEET

This is a different well (use continuation sheet for Class A & B)
PVK 2/15/91

PROJECT: Senior Citizens Bldg. DATE OF TEST: 1-28-86

LOCATION OF WELL (Legal Description): Lot 22 Hylan 1984 addition Block 3

WELL DEPTH: 52 FT. CASING: 50 FT SCREEN: None

DATE DRILLING COMPLETED: 10-7-85 DRILLER: Phillips Drilling

STATIC WATER LEVEL (Top of Casing): 28 FT DATE: 1-28-86

Clock Time	Elapsed Time Since Pumping Started/Stopped, Min.	Depth to Water, ft.	Drawdown/Recovery	Pumping Rate, GPM	Remarks
10:25	0	(swl)	0	0	Start
10:25	1	28 ft			
10:30	5	33 1/2		18	
10:35	10	33 1/2		18	
10:40	15	34		18	
10:45	20	34		18	
10:50	25	34		18	
10:55	30	34		18	
11:00	35	35 1/2		18	
11:05	40	35 1/2		18	
11:10	45	35 1/2		18	
11:15	50	35 1/2		18	
11:20	55	35 1/2		18	
11:25	60 (1 hour)	35 1/2		18	
11:35	90	35		18	
12:25	120 (2 hours)	35		18	
12:55	150	35		18	
1:25	180 (3 hours)	35		18	
1:35	210	35		18	Well produced all that pump would pump
2:25	240 (4 hours)	35		18	
	RECOVERY				
	t 0	t'		0	t/t'
	5				
	10				
	15				
	20				
	25				
	30				
	35				

60023515/393101

SC1-14-34

60023515/393101

SC 1-14-34 DC AAI-15

Comments: Well was chlorinated with 1 gallon of Chlorine when drawdown test was completed.

Arnold R. Phillips