

Job # 113

WATER WELL RECORD
STATE OF ALASKA
DEPARTMENT OF NATURAL RESOURCES
Division of Geological & Geophysical Surveys

Drilling Permit No. 0244687
A.D.L. No. 0244687

LOCATION OF WELL (Please complete either 1a, 1b or 1c.)

1a. Borough	Subdivision	Lot	Block	1b. 1/4 qtrs.	Section No.	Township	Range	Meridian
	BEAULIEU	8	2			N	E	
	VIEW EST					S	W	

1c. DISTANCE AND DIRECTION FROM ROAD INTERSECTIONS
MIle 12 NORTH Fork Road

Street Address and Area of Well Location

3. OWNER OF WELL: Mike Smith
Address: HC 67 Box 919 B
Anchor Point, AK 99556

2. WELL LOG	Material Type	Feet Below Surface	
		Top	Bottom
0-1	TOP SOIL / GRASS	10'	4"
1-18	BROWN CLAY / SAND	10'	0"
18-22	GRAY CLAY / SAND	20'	4"
22-25	GRAY CLAY / COAL	10'	1"
25-30	BROWN SAND	30'	5"
30-41	GRAY CLAY / COAL	10'	0"
41-50	COAL	40'	5"
50-55	GRAY CLAY	10'	0"
55-69	COAL	50'	5"
69-72	FINE SAND / COAL	10'	0"
72-80	COAL / CLAY / HARD SILT	60'	5"
80-82	FINE SAND / Rusty WATER	10'	0"
		70'	5"
82-85	hard silt	10'	0"
85-86	hard shale	30'	5"
86-88	GRAY CLAY	10'	0"
88-95	Rusty SAND	90'	5"
95-102	GRAY SAND	10'	0"
102-110	GRAY SILT / COAL	100'	5"
		3'	5"
		104'	0"

4. WELL DEPTH: (final) 110 ft.

5. DATE OF COMPLETION 10-21-89

6. ☒ Cable tool ☐ Rotary ☐ Driven ☐ Dug
☐ Auger ☐ Jetted ☐ Bored ☐ Other:

7. USE: ☒ Domestic ☐ Public Supply ☐ Industry
☐ Irrigation ☐ Recharge ☐ Commercial
☐ Test Well ☐ Other:

8. CASING: ☐ Threaded ☒ Welded
diam. 1 1/2 in. to 104 ft. Depth Weight 17 lbs./ft.
diam. 6 in. to 104 ft. Depth Stickup 2 ft.

9. FINISH OF WELL:
Type: PERFORATED Diameter: _____
Slot/Mesh Size: 1/4 X 3" Length: _____
Set between 80' ft. and 81' ft.
Backfilling _____ Gravel pack _____

10. STATIC WATER LEVEL: 60 ft. 10/28/89
☐ Above or ☒ Below land surface TOC Date
Equipment used: WELL SOUNDER

11. PUMPING LEVEL below land surface and YIELD
7.5 ft. after 2 hrs. pumping 3 g.p.m.
_____ ft. after _____ hrs. pumping _____ g.p.m.

12. GROUTING Well Grouted: ☒ Yes ☐ No
Material: ☐ Neat Cement ☐ Other: Dentonite

13. PUMP: (if available) HP 2hp Goulds
Length of Drop Pipe 101 ft. capacity 4 g.p.m.
☒ Subm. ☐ Jet ☐ Centrifical ☐ Other

14. REMARKS:
4gpm Restrictor installed ON Pump

15. Water Temperature 7 ☐ F ☐ C

16. WATER WELL CONTRACTOR'S CERTIFICATION:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief;

THE WATER CO. AA-15383
Registered Business Name Contract License Number
Address: Box 569 Anchor Point AK 99556
Signed: James J. CWD/PT Date: 10/4/89
Authorized Representative