



DRILLING & CONSTRUCTION
GENERAL CONTRACTOR



238914

LOCATION OF WELL (Please complete either 1a, 1b or 1c.)

1a. Borough Kenai	Subdivision Quartz Hill	Lot 1	Block 1	1b. 1/4 acre 1	Section No. 1	Township N 1	Range E 1	Meridian W
-----------------------------	-----------------------------------	-----------------	-------------------	--------------------------	-------------------------	------------------------	---------------------	----------------------

1c. DISTANCE AND DIRECTION FROM ROAD INTERSECTIONS Street Address and Area of Well Location	2. OWNER OF WELL: Hameland Enterprises for Drivik Address: POB 1676 Seward AK 99664
--	--

3. WELL LOG	Feet Below Surface		4. WELL DEPTH (feet) 60	5. DATE OF COMPLETION 8-25-92
	Material Type	Top		
	Dirty sand & gravel	0	6	6. ☒ Cable tool ☐ Rotary ☐ Driven ☐ Dug ☐ Auger ☐ Jailed ☐ Bored ☐ Other:
	Silty sand, gravel, cobbles	6	14	
	Sandy gravel	14	22	7. USE: ☒ Domestic ☐ Public Supply ☐ Industry ☐ Irrigation ☐ Reservoir ☐ Commercial ☐ Test Well ☐ Other:
	Silty wet	22	26	
	Silty sand	26	38	8. CASING: ☐ Threaded ☒ Welded diam. 6 in. to 60 ft. Depth Weight 17 lbs./ft. diam. in. to ft. Depth Sitelap 2 ft.
	Silty sand & gravel	38	47	
	Sandy Gravel, silty layers	47	56	9. FINISH OF WELL: Type: open Diameter: 6" Slot/Mesh Size: Length: Set between ft. and ft. Backfilling Gravel pack
	Gravelly sandy cobbles	56	60	
	5" minus			10. STATIC WATER LEVEL: 23'-2" 7/18/97 ☐ Above or ☒ Below land surface Equipment used: TPC
				11. PUMPING LEVEL below land surface and YIELD 23'-10" after 4 hrs. pumping 16 g.p.m. ft. after hrs. pumping g.p.m.
				12. GROUTING Well Grouted: ☐ Yes ☒ No Material: ☐ Neat Cement ☐ Other:
				13. PUMP: (if available) HP 2300 Length of Drop Pipe 40 ft. capacity 12 g.p.m. ☒ Subm. ☐ Jet ☐ Centrifugal ☐ Other
				14. REMARKS: Well was air pumped in excess of 40 gpm for 4+ hrs 6/24/97 - rapid clearing, excellent recovery.

16. WATER WELL CONTRACTOR'S CERTIFICATION:

WOODROW DRILLING & CONSTRUCTION
This well was drilled under my supervision and this report is true to the best of my knowledge and belief.

SEWARD, ALASKA 99664

RICK JONES, OWNER

Signed: **[Signature]**
Authorized Representative

15. Water Temperature **108.30** ° ☐ F ☐ C

Contract License Number


Date: **7/18/97**

Water Wells • Piling • Pumps • Supply & Service

P.O. Box 917 Mile 6.5 Seward Hwy., Seward, Alaska 99664 (907) 224-5602 Fax (907) 224-5603

SB1-1-13C8DD

23894



QUESTA WOODS SUBD. No.6 (SR 98-3) **LOT 14 BLOCK 1 AS-BUILT SURVEY**

Located in the SW1/4 Section 13, T1N R1W, S.M. Alaska
 Seward Recording District

Prepared for
 Homeland Enterprises, Inc.
 P.O. Box 1676
 Seward, AK 99664

Prepared by
 Johnson Surveying
 Box 27
 Clam Gulch, AK 99568

SCALE 1" = 30' **3 July, 1997**



- Notes:
1. No surface waters were noted within 100' of this lot
 2. Lots on all sides of this property are vacant as of July, 1997
 3. No seeps were noted.

