

24102

ECHO LAKE DRILLING CO.

P.O. Box 551

Lester L. Creary

Soldotna, Alaska 99669

Phone 262-4816

September 11, 1997

Mr. Chris Balaska
P. O. Box 2262
Soldotna, Alaska 99669

Re: Water well - 6" drilled and cased.
Lot 7, Miller Ridge Row Subd., K.R.D.

WATER WELL DRILLING LOG

0- 20	Sandy, yellow silt.
20- 35	Fine, silty, brown sand.
35- 60	Medium to fine, loose sand.
60- 72	Medium to fine, brown sand.
72- 94	Fine, silty, brown sand.
94-115	Medium to fine, silty, gray sand.
115-120	Wet, medium to fine, brown sand.
120-135	Wet, medium to coarse, brown sand.
135-190	Medium to coarse sand. Water bearing. (10 ppm Iron)
190-221	Firm, blue clay.
221-234	Wet, blue silt with clay chunks.
234-243	Wet, fine, brown silt.
243-250	Dry, brown silt.
250-278	Stratifies layers of silt and clay. (Oozes water in places.)
278-283	Medium to coarse sand. Water bearing.


12 slot stainless steel screen set at 283 feet.
Static water level - 126 feet from ground level.
Well produces aprx. 25 gallons per minute with 39 feet of draw down.

Field water test:

Iron : 1 Part per million
P.H. : 8
Hardness : 10 grains per gallon

LOCAL NO. SB 3-11-19 DCAR
SITE ID EA 11

24/02



LEGEND

● Found Rebar

△ Vent Pipe

KENAI RECORDING DISTRICT

Plat: 84-197

Date: 10-27-97

Scale: 1"=40'

Drawn: JFS

Job: 97042

Book: 97-2

Disc:

SEGESSER SURVEYS

HC 2 BOX 634
SOLDOTNA, AK 99669
(907) 262-9463

I hereby certify that I have surveyed the following described property:

Lot 7

Ridge Row Subd. Miller 1983 Addn.

and that no encroachments exist except as indicated.

Exclusion Note:

It is the responsibility of the Owner to determine the existence of any easements, covenants, or restrictions which do not appear on the recorded subdivision plat. Under no circumstances should any data hereon be used for construction or for establishing boundary or fence lines.

SB 3-11-19 DCAB