




WS & S Co.

WATER SYSTEMS & SERVICE

Rt 1, Box 1317

Kenai, Alaska 99611

907-776-8066



24143

Dated this Eighteenth day of September, 1997.

~~Mrx~~ New Castle Builders
P.O. Box 456
Kenai, Alaska 99611

Dear ~~Mrx~~ New Castle Builders

The following is a well log which is located on Lot 4
Block North Wood Acre Subdivision Stock Addition
Subdivision, located in the Kenai Recording District. As you
have requested said well to be drilled, we are submitting the
following information regarding your well:

0 To	2 Feet	Top Soil
2 To	31 Feet	Gravel
31 To	45 Feet	Gravel/ Water
To	Feet	
To	Feet	
To	Feet	

Static water level at 31 ' 6 ' of draw down

A submersible pump with a rating of 1/2 h.p. was set as
requested and the well yield has the capacity of 11 g.p.m.
A screen ~~was~~ wasn't set as requested or required.

We thank you for choosing Water Systems & Service Company to
serve your water well needs. If you have any further questions
or problems, please call .

Sincerely,

Kenneth D. Dyer or Antionette R. Dyer
Owners

LOCAL NO. SB 7-12-36A
SITE ID

NK 26

