



WS & S Co.

WATER SYSTEMS & SERVICE

Rt. 1, Box 1517

Kenai, Alaska 99611

907-776-8066

24494

LA 22294

Dated this Twenty Eighth day of May, 1998

COMMUNITY WELL

XXXX Hall Quality Builders
P.O. Box 2829
Kenai, Alaska 99611

Dear MXX Hall Quality Builders

The following is a well log which is located on Lot 266
Block Willow Brook North Commercial Well # 2 #2
Subdivision, located in the Kenai Recording District. As you
have requested said well to be drilled, we are submitting the
following information regarding your well: (±404 ± 0.8 ft)

0	To	2	Feet	Top Soil
2	To	8	Feet	Sand
8	To	32	Feet	Gravel/ Sand
32	To	53	Feet	Clay
53	To	74	Feet	Gravel/ Sand
	To		Feet	

Static water level at 48 ' 12 of draw down


A submersible pump with a rating of 5 h.p. was set as
requested and the well yield has the capacity of 75 g.p.m.
A screen was/~~XXXXXX~~ set as requested or required.

We thank you for choosing Water Systems & Service Company to
serve your water well needs. If you have any further questions
or problems, please call .

Sincerely,

Kenneth D. Dyer or Antionette R. Dyer
Owners

SBS-11-15 DDD


**W S & S CO.**
WATER SYSTEMS & SERVICE

Rt 1, Box 1317

Kenai, Alaska 99611

907-776-8066

380 P05



Project: Hall Quality Builders Commercial Well # 2
Project No.: Lot 266 Willow Brook North
Comp. By: Water Systems & Service Co.
Date: 5/28/98

WELL CASING:

Diameter: 6"

Depth: 74'

Hgt. above Ground: 2.5

WATER LEVEL:

Static: 48'

Drawdown: 12'

Recovery: <20 min

PUMP:

Type: 5 hp

Depth: 63'

SCREEN: 1

Depth: 69' to 74'

Size: # 40

WATER SYSTEM FLOW TEST

<u>Time</u>	<u>Elapsed Time Min.</u>	<u>Depth To Water, Ft.</u>	<u>Drawdown/ Recovery</u>	<u>Flow</u>	<u>Total Gallons</u>
10:00 am	0	48 (swl)	0	0 GPM	0
10:30	30	60	12'	75	2250
11:00	60	60	12'	75	4500
11:30	90	60	12'	75	6750
12:00 pm	120	60	12'	75	9000
12:30	150	60	12'	75	11250
1:00	180	60	12'	75	13500
1:30	210	60	12'	75	15750
2:00	240	60	12'	75	18000

Recovery

10:00am 5/29/98	60	0	0
10:10	10	53	7
10:20	20	48	12
10:30	30	48	12
10:45	45	48	12
11:00	60	48	12

Andrew R. Dyer
Signature

5-28-98
Date

Flow Test continued from Commercial Well # 2
Willow Brook North Lot 266

<u>Time</u>	<u>Elapsed Time Min.</u>	<u>Depth To Water, Ft.</u>	<u>Drawdown/ Recovery</u>	<u>Flow</u>	<u>Total Gallons</u>
3:00	300	60	12'	75	22500
4:00	360	60	12'	75	27000
5:00	420	60	12'	75	31500
6:00	480	60	12'	75	36000
7:00	540	60	12'	75	40500
8:00	600	60	12'	75	45000
9:00	660	60	12'	75	49500
10:00	720	60	12'	75	54000
11:00	780	60	12'	75	58500
5/29/98 12:00 am	840	60	12'	75	63000
1:00	900	60	12'	75	67500
2:00	960	60	12'	75	72000
3:00	1020	60	12'	75	76500
4:00	1080	60	12'	75	81000
5:00	1140	60	12'	75	85500
6:00	1200	60	12'	75	90000
7:00	1260	60	12'	75	94500
8:00	1320	60	12'	75	99000
9:00	1380	60	12'	75	103500
10:00	1440	60	12'	75	108000