

01:59 PM ROBERT FRIESEN

907 357 7307

P. 02

MSB Office Bldg

(10.) LOCATION OF WELL:

Borough Matsu Driller's well number _____Tax Lot Lot 1 BIK 5 Brentwood estatesAddress at well location: Palmer-Wasilla Hwy

(2.) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
Abandonment describe procedure in Item 12.

(3.) TYPE OF WELL:

Rotary Air ☒ Driven ☐ Domestic ☒ Industrial ☐ Municipal ☐
Rotary Mud ☐ Dug ☐ Irrigation ☒ Test Well ☐ Other ☐
Cable ☐ Bored ☐ Withdrawal ☐ Reinjection ☐
Thermal: _____

(4.) PROPOSED USE (check):

(11.) WATER LEVEL: Completed Well

Static Level 60 ft. Below land surface Date 8-5-99

Adhesion pressure _____ lbs. per square inch Date _____

(5.) CASING INSTALLED: Steel ☒ Plastic ☐ Threaded ☐ Welded ☒Diam. from 2 ft. to 121 ft Gauge 250
Diam. from _____ ft. to _____ ft Gauge _____

LINER INSTALLED:

Diam. from _____ ft. to _____ ft Gauge _____

(6.) PERFORATIONS:

Perforated? ☒ Yes ☐ NoBest perforator used Holte
Size of perforations _____ in. by _____ in.
100 perforations from 100 ft. to 115 ft.
10 perforations from 68 ft. to 74 ft.
perforations from _____ ft. to _____ ft.

(7.) SCREENS:

Well Screen Installed? ☐ Yes ☒ No

Manufacturer's Name _____

Type _____ Model No _____

Slot Size _____ Slot From _____ ft. to _____ ft.

Slot Size _____ Slot From _____ ft. to _____ ft.

(8.) WELL TESTS:

Breakdown is amount water level is lowered below static level

_____ gal/min. with _____ ft. drawdown after _____ hrs.

_____ gal/min. with _____ ft. drawdown after _____ hrs.

30 gal/min. with drill stem at _____ ft. _____ hrs.

(12.) WELL LOG:

Depth drilled 121 ft. Depth of completed well 121 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	FROM	TO	SWL
Gravel	0	10	
Hardpan	10	55	
Gravel	55	62	
Hardpan	62	68	
SAND & GRAVEL	68	79	
Hardpan	79	90	
SAND & GRAVEL w/ clay	90	115	
Hardpan & SAND	115	121	

30+ gal/minPolicy Number
92-5n-8944-8

DECLARATIONS PAGE

AMENDED AUG 27 1998

STATE FARM FIRE AND CASUALTY COMPANY
4600 25TH AV N EAST, SALEM OR 97313-1000
A STOCK COMPANY WITH HOME OFFICES IN BLOOMINGTON, ILLINOIS