



DRILLING & CONSTRUCTION



13. Borough Kenai		Subdivision 600-Lot 48		Lot	Block	14. ☐ 1/4 sec. ☐ 1/2 sec. ☐ 3/4 sec. ☐ 1 sec.	Section No.	Township N 43	Range 5	E ☐ W ☐	Meridian Seward
15. DISTANCE AND DIRECTION FROM ROAD INTERSECTIONS 5 1/2 of E 1/2 NW 1/4 Sec. 27						16. OWNER OF WELL: Seward Windson Lodge Address: 40 Seward Construction PO Box 1650 Seward, AK 99664					
17. STREET ADDRESS AND AREA OF WELL LOCATION						18. 4. WELL DEPTH: (feet) 62 ft.					
19. 2. WELL LOG						5. DATE OF COMPLETION 4-5-02					
						6. ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Auger ☐ Jetted ☐ Bored ☐ Other:					
Material Type						7. USE: ☐ Domestic ☒ Public Supply ☐ Industry ☐ Irrigation ☐ Recharge ☐ Commercial ☐ Test Well ☐ Other:					
						8. CASING: ☐ Threaded ☒ Welded diam. 6 in. to 64 ft. Depth 17 lbs./ft. diam. _____ in. to _____ ft. Depth Stackup 3 ft.					
Feet Below Surface Top Bottom						9. FINISH OF WELL: Type: Screen Diameter: 6" Slot/Mesh Size: .020 Length: 5'-0" Set between 64 ft. and 69 ft. Backfilling _____ Gravel pack _____					
						10. STATIC WATER LEVEL: 65 ft. 418102 ☐ Above or ☒ Below land surface Date _____ Equipment used: _____					
Stick-up Gravel Fill Dirty sand & gravel Very silty gravel H.O.P. 17 Silty sand, gravel Sand, wood fiber Very silty sand & gravel - brown Cleaner sandy gravel Poor gravel / sand Silty sand Cleaner shale sand / pea gravel Shale sand & gravel some 2" minus						11. PUMPING LEVEL below land surface and YIELD Pump ft. after 45 hrs. pumping 90 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m.					
						12. GROUTING Well Grouted: ☒ Yes ☐ No Material: ☐ Neat Cement ☐ Other:					
						13. PUMP: (if available) HP 3 HP Length of Drop Pipe 47 ft. capacity 6075 g.p.m. ☒ Subm. ☐ Jet ☐ Centrifugal ☐ Other					
						14. REMARKS:					
15. WATER WELL CONTRACTOR'S CERTIFICATION: WOODCROW DRILLING & CONSTRUCTION P.O. BOX 817 SEWARD, ALASKA 99664 PH. 667-224-5802 RICK JONES, OWNER						16. Water Temperature _____ ° ☐ F ☐ C					
						17. This well was drilled to the best of my knowledge and belief; 10830 Contract License Number					
18. Signed: [Signature] Authorized Representative						Date: 4/12/02					

Water Wells ● Piling ● Pumps ● Supply & Service

P.O. Box 917 Mile 6.5 Seward Hwy., Seward, Alaska 99664 (907) 224-5602 Fax (907) 224-5603



PROJECT: Seward Windsong DATE OF TEST: 04/08/02
 LOCATION OF WELL (Legal Description): Sec Log
 WELL DEPTH: 69 FT. CASING: 64 FT. SCREEN: 020 Johnson
 DATE DRILLING COMPLETED: 04/05/02 DRILLER: Ret 5' 10"
 STATIC WATER LEVEL (Top of Casing): 6' 5" FT DATE: 04/08/02

Clock Time	Elapsed Time Since Pumping Started/Stopped, Min.	Depth to Water, ft.	Drawdown/Recovery	Pumping Rate, GPM	Remarks
1445	0	6' 5" (swl)	0	0	Start
1450	1			55	
1450	5	7' 6"	1' 1"	25	Pump 10 min to
1455	10	8' 1"	1' 8"	25	Step up to 226 GPM
1500	15	8' 4"	2' 4"	90	
	20				
	25				
1515	30	8' 5"	2' 5"		
	35				
	40				
1530	45				
	50				
	55				
1545	60 (1 hour)				
	90				
1645	120 (2 hours)				
	150				
1745	180 (3 hours)				
	210				
1845	240 (4 hours)	8' 5"	2' 5"	90	
RECOVERY					
1845	t 0	t'	8' 5"	2' 5"	0
1850	5		6' 10"	0' 5"	0
1855	10		6' 6"	0' 1"	
	15				
1905	20		6' 5"	0	
	25				
	30				
	35				

Comments:

LAS 23873

SB 1-1-27 BAAA