

33284

WHEATON WATER WELLS, INC.
PO Box 871218, Wasilla, AK 99687
(907) 376-2041

WELL LOG

Name: Hall Quality Homes

Address: P.O. Box 1987

City: Palmer **State:** AK **Zip Code:** 99645

Well Site: T17N, R2W, S24

Lot: B3 **Block:**

Additional: set over existing well drilled by Zac's Well Drilling

Well Depth:	226 ft.	From:	To:	Formation:
Below Ground:	224 ft.	216	226	gravel, sand, water
Above Ground:	2 ft.			
Gal/Min:	100 +			original well drilled to 216 ft.
Static Level:	134 ft.			we added 10 ft. and a screen
Casing:	6" ID Steel			
Liner Pipe:	none			
Screened:	5' of 100 slot			
Perforated:	none			
Grouted:	none			
Depth:	n/a			
Develop. Method:	Air			
Use of Well:	Commercial			
Drilling Method:	Rotary			
Fluids Used:	none			
Pump Installed:	none			
Other:	none			

Date Drilled: 5-11-07 **Driller:** Milo Pitner

WELL LOG

Zac's Well Drilling

~ And Pump Service ~

P.O. Box 521068

Big Lake, Alaska 99652

PALMER

~~376-0227~~
745-4877

OWNER <u>Luinda Mc Donnell</u>	DEPTH OF WELL <u>215</u>
<u>P.O. Box 874862</u>	
ADDRESS <u>Wasilla, Alaska 99687</u>	STATIC LEVEL _____
<u>LOT B-3, RANGE 2W</u>	
WELL-SITE <u>Section 24, Township 17N</u>	GALS. PER MIN. <u>50+</u>
DATE <u>6-4-95</u>	SIZE OF CASING <u>6"</u>
<u>376-6994</u>	<u>Total CASING 215</u>

KIND OF FORMATION:

From <u>0</u> Ft. to <u>7</u> Ft. <u>LOAM</u>	From _____ Ft. to _____ Ft.
From <u>7</u> Ft. to <u>50</u> Ft. <u>HARD PAN</u>	From _____ Ft. to _____ Ft.
From <u>50</u> Ft. to <u>55</u> Ft. <u>GRAVELL</u>	From _____ Ft. to _____ Ft.
From <u>55</u> Ft. to <u>190</u> Ft. <u>HARD PAN</u>	From _____ Ft. to _____ Ft.
From <u>190</u> Ft. to <u>210</u> Ft. <u>SILT SAND</u>	From _____ Ft. to _____ Ft.
From <u>210</u> Ft. to <u>215</u> Ft. <u>GRAVELL WATER</u>	From _____ Ft. to _____ Ft.
From _____ Ft. to _____ Ft.	From _____ Ft. to _____ Ft.
From _____ Ft. to _____ Ft.	From _____ Ft. to _____ Ft.
From _____ Ft. to _____ Ft.	From _____ Ft. to _____ Ft.

CONTRACTOR

Static Water Level 124 ft.

Date Level Taken 5-3-07

Date Drilled 6-4-95

Drilled By Zac's Well Drilling

Clock Time	Elapsed Time in Minutes	Depth to Water	Gallons Per Minute	Remarks
10:00 am	0	124'	0	Start Pump
10:01	1	130'	60	
10:05	5	131'	60	
10:10	10	132'	60	
10:15	15	133'	60	
10:20	20	133'	60	
10:25	25	133'	60	
10:30	30	133'	60	Stop Pump

9ft drawdown

rise long term drawdown 11ft
given 92ft of static water \Rightarrow 12% drawdown @ 60gpm
 \Rightarrow 19ft drawdown @ 100gpm
 35ft @ 200gpm

Clock Time	Elapsed Time in Minutes	Recovery	Remarks
------------	-------------------------	----------	---------

