

SAMPLE DATA SHEET

(USE CONTINUATION SHEET FOR CLASS A & B)

PROJECT: WATER WELL #2DATE OF TEST: 9-12-97
7:00 PM TO
7-14-2001

LOCATION OF WELL (Legal Description):

WELL DEPTH: 481' 2" FT.CASING: 4 3/4" 1" (8")
4 3/4" 1" 6 FTSCREEN: 21' 8" .010DATE DRILLING COMPLETED: 9-10-97DRILLER: ROY LONGBOTHAM JrSTATIC WATER LEVEL (Top of Casing): 8'0DATE: 9-10-97

Clock Time	Elapsed Time Since Pumping Started/Stopped, Min.	Depth to Water, ft.	Drawdown/Recovery	Pumping Rate, GPM	Remarks
9/12/97	0	(SWI)	0	0	Start
7:00 PM	1	90	10'	60	VERY STRONG
	5				WELL
	10				
	15				
	20				
	25				
	30				
	35				
	40				
	45				
	50				
	55				
	60 (1 hour)				
	90				
	120 (2 hours)		10' 2"	60	" "
	150				
	180 (3 hours)				
	210				
	240 (4 hours)		10' 3"	60	" "
	270				
	300				
	330				
	360				
	RECOVERY				
9/14/97	0	79'		0	2:15'
	5				
	10				
	15				
	20				
	25				
	30				
	35				

REMARKS: RUN TEST PUMP AT 60 GAL @ MIN. FOR 27 MIN. NON STOP. STOPPED AT 7:00 AM 9/14/97 STOPPED PUMP & CHECKED STATIC LEVEL (ABOUT) 2 MIN. IT WAS ALREADY UP TO 77 FT. 1 FT. HIGHER THEN WHEN IT WAS STARTED 24 HOURS LATER STATIC LEVEL WAS STILL AT 77 FT.