

Copy to: Midnight Sun Council
Log # 452-1977

6-24-94

J. & O. DRILLING

1060 BIRCH ST.
 FAIRBANKS, ALASKA 99701
 452-4538

Well #1

WELL LOG**OWNER:****MATERIAL**

From

To

Name

Bay Scotts

Address

1400 Gilliam way

Well location

T.7S. R5E. Sec 23 Lake

Type of well

Rotary Drilled

Proposed use

Domestic

Casing installed:

threaded

weld

X6

"dia.

0

ft. to

60

ft. Gauge

250

"dia.

ft. to

ft. Gauge

Perforated:

yes

no

X

size

perf. from

ft. to

ft.

perf. from

ft. to

ft.

perf. from

ft. to

ft.

Screen Installed:

NO

Mfg.

Dia.

slot

from

ft. to

ft.

Water level from top of ground to water

static level

35

Date

4-8-82

Well Test

approx 50 GPM

pump test

NO

yield

GPM

ft.

drawdown. Hours pumped

Construction:

Well seal used

yes

depth

60

size

2"

Gravel pack

NO

from

ft. to

ft.

Drive shoe

NO

depth well drilled

90

Dia. of well below casing

6"

Frozen silt

025

Hard rock

2565

Hard Rock/water

6590

Work started

finished

Pump installed

date

brand

S/N.

model

hp

volt

depth

ft.

Pitless

size

depth

ft. below ground

well cap used

size 6x1

brand

Simmons

This well was constructed under my direct supervision,
 materials used and information reported above are true to
 my best knowledge and belief.

Signed

Jim Turner

date

4-8-82