


## STATE OF ALASKA 74918 DEPARTMENT OF NATURAL RESOURCES DIVISION OF MINING, LAND & WATER Alaska Hydrologic Survey

## WATER WELL LOG Revised 08/18/2016

| Drilling Started:/ Comp   |                               | _ Compl  | leted: 1 / 1 / 1974 Pump Install://                |  |  |
|---|-------------------------------|--|--|--|--|
| City/Borough  | Subdivision                   | Block  | Lot  | Property Owner Name & Address  |  |
| Matanuska-Susitna Borough   | TOWNSHIP 17N RANGE 1E SECTION | 10   | C5   | Alaska Garden Gate Bed And Breakfast AK,   |  |
| Well location: Latitude 61.5729802 Longitude -149.2606255   |                               |  |  |  |  |
| Meridian S Township 017N Range 001E Section 10 , SW 1/4 of NW 1/4 of SE 1/4 of SW 1/4   |                               |  |  |  |  |
| BOREHOLE DATA: (from ground surface) Suggest T.M. Hanna's hydrogeologic classification system* https://my.ngwa.org/NC   |                               |  | Well use:  | thod: Air rotary, Cable tool, Other Public supply, Domestic, Reinjection, Hydrofracking cial, Observation/Monitoring, Test/Exploratory, Cooling,                           |  |
|   | From                          | <u>To</u>  |  | /Agriculture, ☐Grounding, ☐Recharge/Aquifer Storage,   |  |
|   |                               |  | Heating,   | ☐Geothermal Exploration, ☐Other  |  |
|   |                               |  | Fluids used  |  |  |
|   |                               |  |  | ole: 332 ft Casing stickup:ft  |  |
|   |                               |  |  | e: inches  |  |
|   |                               |  | _  | meter: inches Casing depth: 332 ft   |  |
|   |                               |  | Note:  | Depth: ft Diameter:inches  |  |
|   |                               | Well intake opening type: ☐ Open end, ☐ Open hole, ☐ Other |  |  |  |
|   |                               | Screen type:, Screen mesh size:                            |  |  |  |
|   |                               |  | Screen start:ft, Screen stop:ft, Perforated Yes No |  |  |
|   |                               |  |  | description: Perf from: ft, Perf   |  |
|   |                               |  |  | _ft, Perf from: ft, Perf to: ft  |  |
|   |                               |  | Gravel pac   | ked ☐Yes 	■No Gravel start: ft , Gravel stop: ft   |  |
|   |                               |  | Note:  |  |  |
|   |                               |  | Static wate  | er (from top of casing): 125 ft on // Artesian well  |  |
|   |                               |  | Pumping le   | evel & yield: feet after hours at gpm  |  |
|   |                               |  | Method of  | testing:   |  |
|   |                               |  |  | ent method: Duration:<br>ate: gpm  |  |
|   |                               |  |  | :  |  |
|   |                               |  |  | mft, Toft  |  |
| Include description or sketch of well location (include road names,   |                               | Final pump intake depth: ft Model:                         |  |  |  |
| buildings, etc.):   |                               |  | Pump size: hp Brand name:                          |  |  |
|   |                               |  |  | isinfected upon completion? Yes No   |  |
|   |                               |  |  | disinfection:  |  |
| <b>↑</b>  |                               |  |  | quality tested? Yes No   |  |
|   |                               |  | Water qual   | ity parameters tested:   |  |
|   |                               |  | Well driller                                       | name:  |  |
|   |                               |  |  | name: ALASKA RIM ENGINEERING   |  |
|   |                               |  | Mailing add  | dress:   |  |
|   |                               |  | City:  | State: <u>AK</u> Zip:  |  |
| AS 41.08.020(b)(4) and AAC 11 AAC 93.140(a) require that a copy of the well log be submitted to the Department of Natural Resources within <b>45 days of well completion</b> . Well logs may be submitted using the online well log reporting system available at:  https://dnr.alaska.gov/welts/ |                               |  | Phone num  | nber: ()   |  |
|   |                               |  | Driller's sig                                      | nature:  |  |
|   |                               |  | Date:  |  |  |
|   |                               |  | that a copy of                                     | Municipal Code 15.55.060(I) and North Pole Ordinance 13.32.030(D) require of this well log be submitted to the Development Services Department/City ys of well completion. |  |
| OR email electronic well logs to  |                               |  | City Permit I                                      | Number:<br>e:/   |  |
| dnr.water.reports@alaska.gov  |                               |  |  | e:ification Number:  |  |
|   |                               |  |  |  |  |

PĄZOJĄLYGO335 GARDEN GATE SITE PLANYQ700 DrawingN703 Display Drawings(Well No 1 As Built Well Profilectorg, 6/22/7015 3:26.70 PM



## Wheaton Water Well, Inc.

907-376-2041 - Pax: 907-376-2030 - email: brianw@wheatonwells.com 1190 N. Wasilla-Fishhook Road Wasilla, AK 99654

Re: Marska Conden Corte BEB

ON MAY 21, 2015, WHEATON WATER WELL, INC. EXCAVATED AROUND THE EXISTING WELL TO 6" BELOW THE PITLESS. WE INSTALLED 8" CASING AROUND THE WELL AND FILLED THE VOID WITH BAROID CASING SEAL. WE BACKFILLED THE HOLE AND REMOVED THE 8" CASING.

ALL WORK PERFORMED AT THE FOLLOWING LOCATION:

T17N, R1E, S10 LOT C5 950 S. SNODGRASS DRIVE

**BRIAN WILLE** 

WHEATON WATER WELL, INC.