



E&D Water Wells

3530 West Spence Ln.
Wasilla, AK 99623
(907) 373-1598 Fax: (907) 357-1598



Borough	Subdivision	Lot	Block	Section QTRS.	Section	Township	Range	Meridian
MAASU	SOUTHLAND	9	8					SEWARD
Location / Sketch <u>6267 S. DUNCAN</u>				Well Owner <u>MAAS COMPANY</u>				
Depths Measured From: ☒ Casing Top ☐ Ground Surface				Well Depth: _____ Date Of Completion _____				
Borehole Data: Material Type & Color				Depth From To				
<u>Stick-up</u>				<u>0</u> <u>3</u>				
<u>Sand, Gravel</u>				<u>3</u> <u>30</u>				
<u>Gravel, fine clay</u>				<u>30</u> <u>75</u>				
<u>Sand, Gravel, Moisture</u>				<u>75</u> <u>85</u>				
<u>Gravel, fine clay</u>				<u>85</u> <u>150</u>				
<u>Water, Gravel</u>				<u>150</u> <u>181</u>				
				Depth To Static Water Level: <u>146</u> Ft. Below ☒ Top of Casing ☐ Ground Surface				
				Date: <u>2/10/22</u>				
				Method Of Drilling: ☐ Air Rotary ☐ Cable Tool ☐ Other: _____				
				Use Of Well: ☒ Domestic ☐ Irrigation ☐ Monitor ☐ Public Supply ☐ Other				
				Casing Stick-Up: <u>3</u> Ft. Diam: <u>6</u> In. to _____ Ft. Casing Type: <u>A53B</u> _____ In. to _____ Ft.				
				Well Intake Opening Type: ☒ Open End ☐ Screened ☐ Perforated ☐ Open Hole				
				Depths Of Openings: <u>180</u> To: <u>181</u> Ft.				
				Screen Type: <u>N/A</u> Diameter: _____ In. _____ Slot/Mesh Size: _____ Length: _____ Ft. _____				
				Gravel Pack Type: <u>N/A</u> Volume Used: _____ Depth to Top: _____				
				Grout Type: <u>N/A</u> Volume: _____ Depth: From _____ Ft. to _____ Ft. _____				
				Development Method: <u>AK</u> Duration: <u>1hr</u>				
				Pumping Level & Yield: _____ Ft. After _____ Hrs. Pumping <u>25</u> gpm				
				Pump Intake Depth: _____ Ft. Horsepower: _____ Well Disinfected Upon Completion? ☐ Yes ☒ No				

CONTRACTOR INFORMATION:

E&D Water Wells, LLC.
Registered Business Name
Thad Ben 2/10/22
Signature of Authorization Representative Date

REMARKS: JOB# 012020922