



E&D Water Wells

3530 West Spence Ln.
Wasilla, AK 99623
(907) 373-1598 Fax: (907) 357-1598



Borough <i>MATSU</i>	Subdivision <i>BOREALIS HEIGHTS PHASE 1</i>	Lot <i>3</i>	Block <i>1</i>	Section QTRS.	Section	Township	Range	Meridian <i>SEWARD</i>
Location / Sketch <i>8175 S. A STREET</i>				Well Owner <i>ALASKIAN SONS CONST.</i>				
Depths Measured From: ☒ Casing Top ☐ Ground Surface				Well Depth: <i>141</i> Ft. Date Of Completion: <i>2/11/22</i>				
Borehole Data: Material Type & Color				Depth From To				
<i>Stick-up</i>				<i>0</i> <i>3</i>				
<i>Sand, Gravel</i>				<i>3</i> <i>45</i>				
<i>Clay, Gravel, moisture</i>				<i>45</i> <i>55</i>				
<i>Water, Gravel, sand</i>				<i>55</i> <i>85</i>				
<i>Clay, Water, silt</i>				<i>85</i> <i>130</i>				
<i>Clay</i>				<i>130</i> <i>141</i>				
				Depth To Static Water Level: <i>66</i> Ft. Below ☐ Top of Casing ☐ Ground Surface Date: <i>2/11/22</i>				
				Method Of Drilling: ☒ Air Rotary ☐ Cable Tool ☐ Other: _____				
				Use Of Well: ☐ Domestic ☐ Irrigation ☐ Monitor ☐ Public Supply ☐ Other				
				Casing Stick-Up: _____ Ft. Diam: _____ In. to _____ Ft. Casing Type: _____ In. to _____ Ft.				
				Well Intake Opening Type: ☐ Open End ☐ Screened ☒ Perforated ☐ Open Hole				
				Depths Of Openings: <i>75</i> To: <i>80</i> Ft.				
				Screen Type: <i>N/A</i> Diameter: _____ In. _____ Slot/Mesh Size: _____ Length: _____ Ft. _____				
				Gravel Pack Type: <i>N/A</i> Volume Used: _____ Depth to Top: _____				
				Grout Type: <i>N/A</i> Volume: _____ Depth: From _____ Ft. to _____ Ft. _____				
				Development Method: <i>AC</i> Duration: <i>1h</i>				
				Pumping Level & Yield: _____ Ft. After <i>1</i> Hrs. Pumping <i>10</i> gpm				
				Pump Intake Depth: _____ Ft. Horsepower: _____ Well Disinfected Upon Completion? ☐ Yes ☒ No				

CONTRACTOR INFORMATION:

E&D Water Wells, LLC.
Registered Business Name
Michael Ben
Signature of Authorization Representative
2/14/22
Date

REMARKS: *55'-85' zone*

*Was heaving & had to be
Perforated. Unfortunately we could
only find a safe place to perf. at
141' outside of the silt & clay water.
JOB # 013021122*