



6830 E Green Glen Dr.
Wasilla, AK 99654

E-mail: carin@akclearwaterwells.com
www.alaskaclearwaterwells.com

Pump Installation Log Only: ☐

Borough: Mat-Su

Property Owner: Mary Preston

Owner Address:

Latitude: 61.485904 Longitude: -149.6741719 Meridian: Seward T: R: Section:

Borehole Data:	Depth (ft)
Soil Type, Thickness & Water Strata	From To

[illegible]

Installer: Wyatt Renner Date: 04/15/2022

Method of Drilling ☒ air rotary ☐ cable tool

Casing type: Steel A53B Well Depth: 195 feet

Wall Thickness: .25

Diameter: 6 inches Casing Depth: 185

Liner Type: _____ Diameter: _____ inches

Liner Start: _____ feet Stop: _____ feet

Casing stickup above ground: 2 feet

Static water level (from top of casing): 45 feet

Pumping Level and Yield: ☐ Artesian Well

feet after hours pumping

Recovery Rate: 20 gpm

Development Method: Air

Duration: 1 hours

Well Intake Opening Type:

☐ Open End ☐ Open Hole ☒ Screened

Type: 25 slot sand screen

Start	185	feet	Stopped	195	feet
-------	-----	------	---------	-----	------

☐ Perforated	Start	feet	Stopped	feet
-------------------------------------	-------	------	---------	------

Type: _____

Gravel Packed: ☐ Yes ☐ No

Grout Type: Volume:

Depth: Start feet Stopped feet

Well Disinfected Upon Completion? ☐ Yes ☐ No

Method of Disinfection: _____

Comments: _____

Driller/Installer: Rusty Meyer

Signed: Date: 04/15/22